


BSSM48-15 ETL

STAINLESS STEEL EXHAUST HOOD

N.S.F. LISTED. CONFORMS TO NFPA96

Hood Constructed with continuous liquid-tight weld in conformance to IMC 2024 507.2.5.

Hood material: 18 Gauge 430 STAINLESS STEEL (#3 polish) where exposed.



MODEL INFORMATION							
TYPE	DIMENSIONS			CFM SPECS		WEIGHT	
	LENGTH	WIDTH	HEIGHT	EXHAUST PLENUM	SUPPLY PLENUM		
I	180"	51"	24"	4500 @ 0.5 ESP	3600 @ 0.12 ESP	511 lbs	

OBS.:
Installing contractor have the responsibility to ensure hood clearance from limited-combustible and combustible materials is compliant with local code requirements.

STANDARD COMPONENTS INCLUDED							
MOUNTING BRACKET 12-GAUGE GALVANIZED		Light Fixture	Standoff	Grease Drain	Grease Cup Stainless Steel NSF	Grease Filter Stainless Steel UL 1046	
QTY		UL Listed (Included Component)	3" back standoff included	QTY	QTY	QTY	Length Height
6		QTY		2	2	0.00	16" 16"
		3				4.00	20" 16"
						4.00	25" 16"

COMPONENTS						
Exhaust Collar		Supply Collar (Built-in Fire Damper) ¹		Side Standoff	Shipping Crate	
					Dimensions (in) and Weight (lb)	
16-Gauge Cold Rolled Build		16-Gauge Cold Rolled Build		<div><input type="checkbox"/> NONE <input type="checkbox"/> 3" <input type="checkbox"/> _____</div>	Length:	184"
					Width:	55"
QTY	Size	QTY	Size		Height:	32"
2	14.00"x 15.00"	3	10"x16"		Weight:	661 lbs

¹ BUILT-IN MAKE UP AIR PLENUM HOODS are REQUIRED to have fire dampers, according to the NFPA 96.


IMPORTANT:

- 1- Drawing presented shows a typical overview of a Hood system installation, and is not intended to be used for permitting purposes.
- 2- It is the responsibility of the installing contractor to assure that the hood, grease duct and fire suppression system are installed in compliance with NFPA17A, NFPA70, NFPA72, NFPA 96, IMC, state and local codes.
- 3- The hood drawing presented on this document may vary based on which optional components were installed upon the client's request.
- 4- It is the responsibility of the installing contractor to observe field dimensions required based on hood spec, ductwork and options installed.
- 5- BUILT-IN MAKE UP AIR PLENUM HOODS are REQUIRED to have fire dampers, according to the NFPA 96.




PO BOX 47607 - ATLANTA, GA 30360
PHONE: 770.936.0770 - www.superiorhoods.com

PROJECT		BSSM48-15 ETL		
TITLE		MODEL BSSM48 ETL STANDARD SUBMITTAL SHEET		
APPROVED		CODE		DWG NO
CHECKED				REV 01
DRAWN	PRODUCTION	2025	SCALE: 1:34	WEIGHT: 511 lbs SHEET: 1/2





Mounting Bracket Assembly
Recommended:

- Threaded Rod not
smaller than 3/8"



ITEM	DESCRIPTION
A	Exhaust Fan
B	Grease Trap Box drain pipe
C	Grease Trap Box
D	Exhaust Curb 22" Tall Typ.
E	16-Gauge cold rolled steel grease duct liquid-tight welded
F	Exhaust Riser
G	Built-in 3" Standoff
H	UL 1046 Approved Stainless Steel Grease Filter
I	Stainless Steel 1" Grease Drain Pipe
L	UL Approved Light Fixture
J	Removable Grease Cup not to exceed 1 Gal. Cap
K	Electrical Box
M	16"x10" Fire Dumper
N	Integrated Supply Air Plenum
O	Perforated Aluminum Supply Air Difuser (3003, H14)
Q	Make Up Air Curb 12" Tall Typ
R	Galvanized Make-Up Air Drop
P	Make Up Air Fan
S	Mounting Bracket Assembly



 PO BOX 47607 - ATLANTA, GA 30360 PHONE: 770.936.0770 - www.superiorhoods.com		PROJECT BSSM48-15 ETL	
		TITLE TYPICAL HOOD SYSTEM INSTALLATION	
APPROVED	CODE	DWG NO	REV 01
CHECKED			
DRAWN	PRODUCTION	2025	SCALE: 1:28
			SHEET: 2/2