



T&S BRASS AND BRONZE WORKS, INC.
 2 SADDLEBACK COVE / P.O. BOX 1088 / TRAVELERS REST, SC 29690
 PHONE 800-476-4103 - FAX 864- 834-3518



Sales No.


EW-SP21FC

RELIABILITY
 BUILT IN

Job Name:

Architect/Engineer Approval:

Notes:



NOTES:

1. CERTIFIED TO ANSI STANDARD Z358.1 (LATEST REV.)
2. DESIGN FOR 2.5 GPM FLOW WITH 30 TO 90 PSI

Product Description:
 EYE WASH w/ DUST COVER ASSEMBLY

Drawn: DMH	Checked GEF	Scale: 1:1
Approved JHB		Date: 12/20/10