





COOLER




STANDARD WITH FLOOR COOLER DETAIL ①



OPTION A DOOR SWING



OPTION B DOOR SWING



DOOR ELEVATION
46x82.25DS 26x78 DR P-P-CLR STD
THRESHOLD DETAIL 01

LH SHOWN
RH OPPOSITE

WALK-IN SPECIFICATIONS

SIZE: 7'-9" X 9'-8" X 7'-6 1/4"

PANELS: ALL FOAMED PANELS ARE 4"
EXTERIOR FINISH: ALL 26GA STUCCO GALVALUME
INTERIOR FINISH: ALL 26GA STUCCO GALVALUME

FLOOR TYPE: COOLER - .100 SMOOTH ALUMINUM

HEIGHT: OD 7'-6 1/4" ID 6'-10 5/8"

DOORS: 46x82.25DS 26x78 DR STD CLR
115-60-1/1.0 AMPS

ACCESSORIES: (NONE)

REFRIG. PC069T2 3/4HP 115/60/1 16.3 AMPS

USE this drawing for installation



- IMPORTANT NOTES:**
- 1) ALLOW MINIMUM 1" CLEARANCE ALL AROUND WALK-IN.
 - 2) WALK-IN CEILING IS NOT DESIGNED FOR FOOT TRAFFIC OR STORAGE.
 - 3) GENERAL CONTRACTOR TO REFER TO DESIGN AND SPECIFICATIONS MANUAL FOR FLOOR DETAIL INFORMATION.
 - 4) SPECIAL NOTE TO GENERAL CONTRACTOR AND SUBCONTRACTOR FOR QUARRY TILE OR CONCRETE WEARING FLOOR - THE SHEET METAL PANEL FACINGS MAY BE SUSCEPTABLE TO STAINING DUE TO EXCESSIVE MOISTURE CREATED BY THE HYDRATION OF CONCRETE TYPE MATERIALS. THEREFORE, IT IS ABSOLUTELY NECESSARY THAT EACH ROOM BE PROPERLY VENTILATED. ALSO NOTE THAT SPECIAL PRECAUTIONS MUST BE TAKEN WHEN USING MURIC ACID DUE TO EFFECTS HYDROCHLORIC ACID FUMES HAVE ON ALUMINUM AND STAINLESS STEEL MATERIALS.

SCALE:	3/8"=1'-0"	DRAWING NO.:	P7-810-CT
DRAWN BY:	SHW	DATE:	01/25/2008
DEALER:		PROJECT:	7'-9" X 9'-8" X 7'-6 1/4"
5015 TENNESSEE AVENUE NORTH P.O. BOX 850 FAIRBORN, TN 38860 (801) 847-6861		KOLPAK WALK-INS	